


|   |  |  |
|---|--|--|
|  | <b>GEBATOUT 2 +<br/>FILASSE DE LIN<br/>RT1</b> | Nanteuil le Haudouin,<br>le 5 juillet 2018 |
|---|--|--|

## ATTESTATION

Nous soussignés, certifions que le couple **GEBATOUT 2 + FILASSE DE LIN RT1** est compatible avec les installations d'eau destinée à la consommation humaine :

- Certificat de Conformité aux Listes Positives de référence n° 18 CLP LY 007
- Attestation WRAS n° 1806512

GEB SAS Laboratoire Recherche & Développement

# CARSO - LABORATOIRE SANTÉ ENVIRONNEMENT HYGIÈNE DE LYON

Laboratoire Agréé pour les analyses d'eaux par le Ministère de la Santé

Laboratoire habilité par le Ministère chargé de la santé en application de l'article R\*.1321-52 du code de la santé publique

## CERTIFICAT DE CONFORMITE AUX LISTES POSITIVES DE REFERENCE Certificate of conformity to positive lists

Conformément à l'arrêté du 29 mai 1997 modifié, aux circulaires du Ministère chargé de la santé  
DGS/VS4 n° 99/217 du 12 avril 1999 et DGS/VS4 n° 2000/232 du 27 avril 2000  
et à l'avis paru au Journal Officiel du 24 février 2012 (texte n°119)

Coordonnées du demandeur :  
Contact details of the ACS owner

**GEB**

**1, Allée des Coquelicots  
60440 NANTEUIL LE HAUDOIN**

Nom(s) commercial(aux) du produit fini :  
Commercial name(s) of the finished product

**Gebatout 2 + Filasse de Lin RT1**

Type de produit fini / Type of finished product :

- Lubrifiant / Lubricant     Ajout ou Adjuvant organique pour ciment / Organic cement admixture  
 Graisse / Grease     Revêtement à base de ciment / Cementitious coating  
 Colle / Glue     Joint de diamètre inférieur à 63 mm / Seal, gasket, o-ring with a diameter lower than 63 mm  
 Autre / Other : pâte à joint

Commentaires / Comments : graisse et fibres naturelles / grease and natural fibers

Couleur du produit / Product color : naturelle / natural

N° de dossier attribué par le laboratoire habilité / File reference : **18 CLP LY 007**

Formulation chimique / Chemical formulation :

La formulation chimique vérifiée par le laboratoire est conforme aux listes positives de référence. Ce certificat est établi sous réserve de la non-modification de la composition chimique du produit et des préparations commerciales qui le constituent. Il peut par ailleurs être remis en cause par l'évolution des listes positives.

The chemical formulation checked by the laboratory is conform to the positive lists. This certificate is issued provided that chemical composition of the product ( and commercial preparations that constitute it) stays unmodified. It can also be reconsidered by the positive lists evolution.

Remarque / Remark : /

Attestation délivrée par / Certificate issued by :

Christelle AUTUGELLE

Signature :

Responsable MCDE

CARSO - L.S.E.H.L.

A la date du / Date of issue : 28 Février 2018

Date d'expiration du CLP / Expiry date : 28 Février 2023

Commentaires / Comments : /



Approval Number: 1806512  
Test Report: MAT/LAB 315B



Water Regulations Advisory Scheme Ltd.  
Unit 13,  
Willow Road,  
Pen y Fan Industrial Estate,  
Crumlin,  
Gwent,  
NP11 4EG

13<sup>th</sup> June 2018

GEB SAS  
1 allée des coquelicots,  
60440 NANTEUIL LE HAUDOIN,  
France

**WATER REGULATIONS ADVISORY SCHEME LTD. (WRAS)**  
**MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

**SEALANTS - SCREWED JOINTS - GENERAL.**

**5510**

'Gebatout2 for use with Filasse RT1'.

Gebatout2 is a grey coloured, synthetic polymer sealing paste which should be applied in accordance with technical datasheet 'version 9' dated 05/09/17.

Filasse RT 1 is a brown coloured, natural linen fibre which should be applied in accordance with technical datasheet 'version 1' dated 12/06/2018.

For use with water up to 85°C.

**APPROVAL NUMBER: 1806512**  
**APPROVAL HOLDER: GEB SAS**

The Scheme reserves the right to review approval.  
Approval 1806512 is valid between June 2018 and June 2023

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: [www.wras.co.uk/directory](http://www.wras.co.uk/directory)

Yours faithfully

A handwritten signature in black ink, appearing to read 'Jason Furnival', written in a cursive style.

Jason Furnival  
Approvals & Enquiries Manager  
Water Regulations Advisory Scheme

## **WRAS MATERIAL APPROVAL - MATERIALS WHICH HAVE PASSED FULL TESTS OF EFFECT ON WATER QUALITY**

The material referred to in this letter is suitable for contact with water for domestic purposes. **Approval of this material does not signify the approval of its mechanical or physical properties for any use.**

Manufacturers or applicants may only quote in their sales literature terms which are used in this letter, namely that; 'the material as listed, having passed the tests of effect on water quality, is suitable for use in contact with wholesome water'

This may be abbreviated to 'Water Regulations Advisory Scheme - Approved Material' or 'WRAS Approved Material'.

The scope of an Approval does not extend to rebranded materials unless otherwise agreed by the Scheme.

### **Use of the WRAS Approved Material Logo**

Approval holders may use the WRAS Approved Material logo and make reference to any approval issued by WRAS Ltd. in respect of a particular material or range of materials provided the approval is, and remains valid.

Approval holders are entitled to use the logo on the packing, promotional literature and point of sale advertising Approved Materials.

### **Modifications to existing Approvals**

It is a condition of WRAS Material Approval that NO changes or modifications to the Approved Material, be made without the Approval Holder first notifying WRAS Ltd. Full details of the proposed changes must be provided to the Scheme. Failure to comply with this condition will immediately invalidate a previously granted Approval.

### **Re-Approval**

WRAS will write to you 1 year before the approval expires asking whether you would like to renew it. Please complete the relevant section of the MA3 application form which will be included with the letter and return to WRAS (via e-mail or post).

Please note it is the responsibility of the Approval Holder to ensure the Approval remains valid. WRAS Ltd. accepts no liability for the delay in granting approval where this is caused by circumstances outside of the Scheme's control.